



Revised Draft Environmental Impact Statement Commonwealth of the Northern Mariana Islands Joint Military Training



Appendix M: Part 2



June 2025
EISX-007-17-XMC-1747255459



Appendix M - Part 2 Utility Studies

Wastewater Analysis

Solid Waste and Hazardous Waste Study Update

Electrical System Analysis

The appendices of this Revised Draft EIS are compliant with Section 508 of the Rehabilitation Act. This allows assistive technology to be used to obtain the available information from the document. However, accessibility is limited to a descriptive title for some graphics, figures, tables, images, and attachments. Individuals who require assistance may submit a request through the Section 508 link on the project website at CNMIJointMilitaryTrainingEIS.com

| | |
|--|--------------|
| WASTEWATER ANALYSIS..... | M-127 |
| 1 Purpose | M-129 |
| 1.1 Description of Proposed Wastewater Infrastructure | M-129 |
| 1.1.1 Base Camp | M-129 |
| 1.1.2 Port of Tinian | M-129 |
| 1.1.3 Francisco Manglona Borja/Tinian International Airport | M-129 |
| 1.1.4 Other Facilities..... | M-129 |
| 1.2 Commonwealth of the Northern Mariana Islands Wastewater Regulations..... | M-130 |
| 1.2.1 Individual Wastewater Disposal System Regulations | M-130 |
| 1.2.2 Other Wastewater Treatment System Regulations | M-130 |
| 1.3 Existing Wastewater Infrastructure..... | M-130 |
| 1.3.1 Existing Individual Wastewater Disposal System Infrastructure | M-130 |
| 1.3.2 Existing Other Wastewater Treatment System Infrastructure | M-132 |
| 1.4 Proposed Wastewater Demand and Wastewater Infrastructure..... | M-134 |
| 1.4.1 Design Population..... | M-134 |
| 1.4.2 Proposed Wastewater Demand | M-134 |
| 1.4.3 Proposed Wastewater Infrastructure | M-134 |
| 1.5 Wash Rack | M-135 |
| 1.6 Vehicle MaintEnAnce..... | M-136 |
| 1.7 Summary | M-136 |
| 2 References..... | M-137 |
| SOLID WASTE AND HAZARDOUS WASTE STUDY UPDATE..... | M-139 |
| 1 INTRODUCTION | M-141 |
| 1.1 Purpose..... | M-141 |
| 1.2 study goals and objectives | M-141 |
| 2 EXISTING AND PLANNED CNMI WASTE DISPOSITION OPTIONS | M-143 |
| 2.1 Tinian PUntan Diablo Disposal Facility..... | M-143 |
| 2.2 proposed atgidon landfill | M-145 |
| 2.3 marpi landfill..... | M-145 |
| 2.4 Tinian transfer station | M-146 |
| 2.5 Construction and Demolition Waste..... | M-147 |
| 2.6 Green Waste..... | M-147 |
| 2.7 Hazardous, Industrial, Universal Wastes and E-Wastes | M-147 |
| 3 PROPOSED ACTION WASTE GENERATION AND CHARACTERIZATION | M-148 |
| 3.1 Solid Waste | M-148 |
| 3.1.1 Construction Waste..... | M-149 |
| 3.1.2 Green Waste..... | M-153 |
| 3.1.3 Hazardous, Industrial, Universal Wastes and E-Wastes | M-155 |

| | | |
|----------|---|--------------|
| 4 | PROPOSED ACTION WASTE GENERATION AND CHARACTERIZATION— TRAINING OPERATIONS..... | M-157 |
| 4.1 | Solid Waste | M-158 |
| 4.1.1 | Solid Waste Generation Rates | M-158 |
| 4.1.2 | Solid Waste Composition and Diversion..... | M-158 |
| 4.1.3 | Solid Waste Quantities..... | M-160 |
| 4.1.4 | Construction Waste | M-164 |
| 4.1.5 | Green Waste..... | M-165 |
| 4.1.6 | Hazardous Waste, Industrial, Universal Wastes, and E-Wastes | M-165 |
| 5 | SOLID AND HAZARDOUS WASTE MANAGEMENT AND DISPOSITION OPTIONS | M-167 |
| 5.1 | Solid Waste Management Requirements | M-168 |
| 5.2 | Impacts to Existing and planned Solid Waste Management Facilities | M-168 |
| 5.2.1 | Tinian Puntan Diablo Landfill | M-169 |
| 5.2.2 | Marpi Landfill..... | M-169 |
| 5.2.3 | Tinian Transfer Station | M-169 |
| 5.3 | Incineration | M-170 |
| 5.4 | Hazardous, Industrial, Universal, and Electronic Waste | M-171 |
| 6 | REGULATORY SETTING | M-173 |
| 6.1 | Commonwealth of the Northern Mariana Islands..... | M-173 |
| 6.1.1 | Bureau of Environmental and Coastal Quality | M-173 |
| 6.1.2 | Coastal Resources Management | M-173 |
| 6.1.3 | Division of Fish and Wildlife | M-174 |
| 6.1.4 | Historic Preservation Office | M-174 |
| 6.2 | United States Government | M-175 |
| 6.2.1 | United States Environmental Protection Agency | M-175 |
| 6.2.2 | Federal Aviation Administration | M-175 |
| 7 | REFERENCES..... | M-177 |
| | STORMWATER STUDY | M-179 |
| 1 | Introduction..... | M-181 |
| 1.1 | Purpose..... | M-181 |
| 2 | Regulatory Framework | M-183 |
| 2.1 | Energy Independence and Security Act of 2007 Section 438..... | M-183 |
| 2.2 | Technical Guidance for the Energy Independence and Security Act Section 438 Implementation | M-183 |
| 2.3 | Department of the Navy Low Impact Development Policy for Stormwater Management..... | M-183 |
| 2.4 | Department of Defense Implementation of Storm Water Requirements under the Energy Independence and Security Act Section 438..... | M-184 |
| 2.5 | Unified Facilities Criteria 3-201-01, Civil Engineering | M-184 |

| | | |
|----------|--|--------------|
| 2.6 | Unified Facilities Criteria 3-210-10, Low Impact Development..... | M-184 |
| 2.7 | National Pollutant Discharge Elimination System Permit Administration..... | M-184 |
| 2.8 | CNMI and Guam Stormwater Management Manual..... | M-184 |
| 2.9 | Range Environmental Vulnerability Assessment | M-186 |
| 3 | Existing Conditions..... | M-187 |
| 3.1 | Topography | M-187 |
| 3.2 | Existing Slope | M-187 |
| 3.3 | Soils..... | M-189 |
| 3.4 | Climate and Hydrology..... | M-189 |
| 4 | Stormwater Considerations | M-191 |
| 4.1 | Assumptions..... | M-191 |
| 4.2 | Depressional Areas | M-192 |
| 4.3 | Protected Surface Waters | M-192 |
| 4.4 | Fault Lines | M-192 |
| 5 | Water Quantity Analysis..... | M-193 |
| 5.1 | Digital Elevation Model Development | M-193 |
| 5.2 | Flow Path Determination and Sub-basin Delineation..... | M-194 |
| 5.3 | Land Use and Land Cover | M-194 |
| 5.4 | Tinian Curve Number Values | M-196 |
| 5.5 | Initial Abstraction/Storage Tinian Curve Number Values..... | M-196 |
| 5.6 | Time of Concentration Tinian Curve Number Values..... | M-197 |
| 5.7 | Design Storm Frequency Tinian Curve Number Values | M-197 |
| 5.8 | Design Rainfall Depths and Distribution Tinian Curve Number Values | M-198 |
| 5.9 | Results of Analysis Tinian Curve Number Values | M-199 |
| 6 | Stormwater Best Management Practices/Integrated Management Practices..... | M-201 |
| 6.1 | Stormwater Management Practices Tinian Curve Number Values | M-201 |
| 6.2 | Water Quality/Low Impact Development Tinian Curve Number Values | M-202 |
| 6.3 | Water Quality and Recharge Volumes Tinian Curve Number Values | M-203 |
| 6.4 | Low Impact Development Application Tinian Curve Number Values | M-205 |
| 6.5 | Integrated Management Practices Tinian Curve Number Values..... | M-205 |
| 6.6 | Base Camp Treatment Options Tinian Curve Number Values..... | M-206 |
| 6.6.1 | Multi-Purpose Maneuver Range and Explosives Training Range Treatment | M-207 |
| 7 | Conclusions..... | M-209 |
| 8 | References..... | M-211 |
| | ELECTRICAL SYSTEM ANALYSIS | M-221 |
| 1 | Purpose | M-223 |
| 1.1 | Background | M-223 |

| | | |
|----------|--|--------------|
| 2 | Existing Electrical System on Tinian | M-226 |
| 2.1 | Commonwealth Utilities Corporation Island-wide System | M-226 |
| 3 | Estimated Electrical Demand and Proposed Electrical Infrastructure with CJMT Action | M-228 |
| 3.1 | Power Demand..... | M-228 |
| 3.2 | Medium Voltage Power Distribution..... | M-230 |
| 3.2.1 | Electrical Distribution System | M-230 |
| 3.3 | quantities – Underground distribution | M-233 |
| 4 | References..... | M-234 |

LIST OF FIGURES

WASTEWATER ANALYSIS

| | |
|--|-------|
| Figure 1. Existing Individual Wastewater Disposal System at USAGM | M-131 |
| Figure 2. Existing Individual Wastewater Disposal System at Camp Tinian..... | M-132 |
| Figure 3. Entrance to the Tinian Dynasty Hotel and Casino | M-133 |
| Figure 4. Other Wastewater Treatment System at Tinian Diamond Hotel and Casino | M-133 |

STORMWATER STUDY

| | |
|---|-------|
| Figure 1. Island of Tinian – Physiographic Regions..... | M-188 |
| Figure 2. Island of Tinian – Hydrologic Soil Groups | M-190 |
| Figure 3. Land Cover on the Island of Tinian..... | M-195 |

ELECTRICAL SYSTEM ANALYSIS

| | |
|---|-------|
| Figure 1. Island of Tinian – Location | M-224 |
| Figure 2. Island of Tinian – Military Lease Area Boundaries | M-225 |
| Figure 3. Existing Electrical Distribution System | M-229 |
| Figure 4. Proposed Electrical Distribution System..... | M-232 |

LIST OF TABLES

WASTEWATER ANALYSIS

| | |
|--|-------|
| Table 1. Peak Proposed Wastewater Demand | M-134 |
|--|-------|

SOLID WASTE AND HAZARDOUS WASTE STUDY UPDATE

| | |
|--|-------|
| Table 1. Proposed Action Project Phasing..... | M-142 |
| Table 2. Estimated 2023 Tinian Puntan Diablo Disposal Tonnage | M-145 |
| Table 3. Estimated Existing (2023) Marpi Landfill Disposal Tonnage..... | M-146 |
| Table 4. Estimated Solid Waste Generation – Construction Phase | M-149 |
| Table 5. Projected Construction Waste Generation..... | M-149 |
| Table 6. Estimated Construction and Demolition Composition for New Structures/Buildings – Construction Phase..... | M-151 |
| Table 7. Estimated Construction and Demolition Composition for New Concrete Surfaced Areas – Construction Phase | M-152 |
| Table 8. Estimated Construction and Demolition Waste Generation, Diversion and Disposal – Construction Phase..... | M-152 |
| Table 9. Projected Green Waste Generation During Construction..... | M-153 |
| Table 10. Estimated Annual Green Waste Generation - Construction Phase..... | M-155 |
| Table 11. Tinian Training Area - Solid Waste Composition During Training | M-158 |
| Table 12. Tinian Training Area – Estimated Recyclable Diversion Rates | M-160 |
| Table 13. Alternative 1 Training Events, Duration, Frequency and Projected Headcount | M-161 |
| Table 14. Training Event Frequency and Personnel Headcount..... | M-161 |
| Table 15. Maximum Solid Waste Generation (per year)..... | M-162 |
| Table 16. Solid Waste Generation (per day)..... | M-163 |
| Table 17. Solid Waste Generation | M-164 |
| Table 18. Expended Ammunition Casing Metals | M-164 |
| Table 19. Projected Construction and Demolition Waste Generation During Training Operations | M-165 |
| Table 20. Existing Disposal Capacity vs. Required Capacity | M-169 |

STORMWATER STUDY

| | |
|--|-------|
| Table 1. Curve Numbers Used for Post-project Land Cover and Soil on Tinian | M-196 |
| Table 2. Rainfall Data per Design Storm..... | M-198 |
| Table 3. HydroCAD Stormwater Parameters | M-200 |
| Table 4. HydroCAD Stormwater Results | M-200 |
| Table 5. Water Quality Volumes | M-204 |

| | |
|---------------------------------|-------|
| Table 6. Recharge Volumes | M-205 |
|---------------------------------|-------|

ELECTRICAL SYSTEM ANALYSIS

| | |
|---|-------|
| Table 1. Electrical Power System Peak Demand and Capacity | M-228 |
| Table 2. Duct Bank Quantities | M-233 |

**ELECTRICAL SYSTEM ANALYSIS
IN SUPPORT OF THE
COMMONWEALTH OF THE NORTHERN MARIANA
ISLANDS
JOINT MILITARY TRAINING ENVIRONMENTAL
IMPACT STATEMENT**



Department of the Navy
Naval Facilities Engineering Systems Command, Pacific
258 Makalapa Drive, Suite 100
JBPHH HI 96860-3134

June 2025

This page is intentionally left blank.

1 PURPOSE

The purpose of this memorandum is to provide technical background and analysis of power distribution in support of the Commonwealth of the Northern Mariana Islands (CNMI) Joint Military Training Revised Draft Environmental Impact Statement (EIS).

1.1 BACKGROUND

The islands of the CNMI are strategically located in the United States (U.S.) Department of Defense (DoD) Indo-Pacific area of operations, as shown in Figure 1. Figure 2 shows the Military Lease Area on Tinian where the U.S. military has trained for several decades.

The Proposed Action would support the ongoing and evolving training requirements of U.S. Armed Forces forward deployed to the Western Pacific, and of U.S. allies and partners, specifically for distributed operations training within the Military Lease Area on Tinian. Proposed training events would include both ground and aviation training within the Military Lease Area.

Non-live-fire offensive and defensive training actions would continue to be conducted in the Military Lease Area with an increase in existing land-based training events, including both ground and aviation training, which are the same or similar to those currently being conducted on Tinian.

Live-fire training would be conducted at two ranges that would be developed within the Exclusive Military Use Area:

- **Multi-Purpose Maneuver Range.** A live-fire range occupying approximately 200 acres at the northern tip of Tinian to support platoon-size live-fire and maneuver, including three surface radar facilities.
- **Explosives Training Range.** A live-fire range on approximately 2.5 acres for the employment of demolitions and military explosives in support of offensive and defensive training events.

The following are also included in the Proposed Action to support training events:

- Establishment of 13 Landing Zones, areas cleared of vegetation to 6–8 inches, and associated access roads to conduct training events and to provide staging, bivouac, and gathering and rendezvous areas.
- Ground and aviation improvements at North Field, including establishment of a drop zone and the placement of a metal airfield surface.
- Construction and operation of a Base Camp.
- Clearance and improvements of roads within the Military Lease Area.



Figure 1. Island of Tinian – Location



Figure 2. Island of Tinian – Military Lease Area Boundaries

2 EXISTING ELECTRICAL SYSTEM ON TINIAN

2.1 COMMONWEALTH UTILITIES CORPORATION ISLAND-WIDE SYSTEM

The Commonwealth Utilities Corporation, a public corporation, owns the existing island-wide electrical distribution system on Tinian. Telesource CNMI, Inc., operates and maintains the system under an Independent Power Provider agreement with the Commonwealth Utilities Corporation. The status of the agreement and whether the Commonwealth Utilities Corporation would inherit the workforce and take over operations, has yet to be confirmed. This would still allow the Commonwealth Utilities Corporation to have flexibility to continue contracting certain items from Telesource CNMI, Inc., if needed. This existing system includes several electrical generation units and distribution infrastructure, which consists of overhead and underground distribution lines, power poles, utility holes, transformers, substations, and meters used to provide and measure power to island customers (Information cited in Cardno GS).

The existing electrical generation system at the powerplant consists of the following components:

- Four 4.16 kilovolt, 2.5 megawatt diesel generators
- Two 4.16 kilovolt, 5.5 megawatt diesel generators
- Two exhaust stacks:
 - One 90-foot tall stack to service four 2.5 megawatt generators
 - One 175-foot tall stack to service two 5.5 megawatt generators
- An aboveground fuel delivery pipeline from the existing diesel fuel storage tank at the Port of Tinian to a diesel storage tank, which is adjacent to the power plant facility
- Expansion capability for two additional 5.5 megawatt diesel generators (including space inside the existing generator building and tie-in points to the existing exhaust stack)

Data collected in the field indicated an installation date of 1999 for the generators.

The location, configuration, and electrical capacity are essential details for the evaluation of the Tinian Power Plant. The Tinian Power Plant is a single generation facility near the coast outside of San Jose at 25 feet above mean sea level. The powerplant has a total generator operating capacity of 18.2 megawatt with available capacity of 12.70 megawatt considering the maintenance scenario of the largest generator to accommodate additional loads. The powerplant's capacity could be expanded because it has space for two additional 5.5 megawatt generators that would provide an additional 11 megawatt to the system capacity, if installed; this would provide a total generator operating capacity of 29.2 megawatt and an available capacity of 24.7 megawatt. The 4,160-volt output from each of the six diesel generators feed the 1200A synchronizing switchgear that in turn feeds step-up transformers.

The step-up transformers increase the 4,160 volt up to 13.8 kilovolt for power distribution, except for Feeder 2, which distributes power at 4,160 volt. This feeder was anticipated to be upgraded from 4,160 volt to 13.8 kilovolt by 2024, and its current status is unknown. The island-wide electrical distribution consists of four medium voltage feeders that originate from the Commonwealth Utilities Corporation plant. Feeder 1 was identified as offline and loads transferred to Feeder 2. Feeders 2 and 3 support most of the island. Feeder 4 is a dedicated feeder that serves

the former U.S. Agency for Global Media (USAGM) facility (Department of the Navy [DON] 2018).

See Figure 3 for existing feeder distribution and designations.

Much of the existing island-wide electrical distribution system is overhead except for lines within the vicinity of the airfield runways. The existing overhead power distribution on the island has been replaced with concrete poles after impacts from Typhoon Yutu in 2018. The extent of how much of the overhead line distribution has been replaced to date has yet to be determined.

A 2017 Tinian Unscheduled Power Outages report received during the site investigation, revealed the following outages:

- 2015 – 11 Emergency Outages
- 2016 – 6 Emergency Outages

No additional information as to the cause of the outage events is known.

3 ESTIMATED ELECTRICAL DEMAND AND PROPOSED ELECTRICAL INFRASTRUCTURE WITH CJMT ACTION

3.1 POWER DEMAND

The existing system capacity at the Tinian power shall not exceed 12.70 MW. Proposed operations would add an estimated 0.146 megawatt of peak electricity demand to operate facilities and supporting infrastructure and equipment. The additional electrical demand loads on the proposed operations include the three surface radar facilities, which may alternatively be powered by temporary or permanent generators. This increase in peak demand accounts for 1.15 percent of total island-wide/Commonwealth Utilities Corporation system capacity. Table 1 provides a summary of existing and proposed electrical demands relative to the existing electrical system capacity. With this added electrical demand, the system maintains a 9.55 megawatt capacity reserve, which is 75.2 percent of the total system capacity (see Attachment A for calculation details). The existing island-wide power generation facility is capable of meeting the increased power demand during the proposed operations; therefore, the impacts would be less than significant.

Table 1. Electrical Power System Peak Demand and Capacity

| <i>Item</i> | <i>MW of Electricity</i> | <i>% of System Capacity</i> |
|--|--------------------------|-----------------------------|
| Tinian Power Plant Effective Design Capacity | 12.70 | 100 |
| Peak Electrical Demand from Existing Customers | 3.00 | 23.5 |
| Additional Peak Electrical Demand from Proposed Facilities | 0.146 | 1.15 |
| Total Electrical Demand with Proposed Facilities | 3.146 | 24.8 |
| Remaining Electrical Generating Capacity with Proposed Action | 9.51 | 75.2 |

Legend: % = percent; MW = megawatt.

Multiple interconnection points to the grid exist. However, a spare breaker is available that could be used for the U.S. Marine Corps (USMC) and, based on peak demand load information received for 2016 and 2017, it is recommended that the USMC be tied to the existing Feeder 4 with the former USAGM infrastructure. Further analysis and investigations and data gathering on peak demand readings are required to validate this recommendation.

Demand load information indicated a peak demand load of 1.4 megawatt on Feeder 4; the demand from the proposed facilities is approximately 0.146 megawatt. The addition of the 0.146 megawatt load on Feeder 4 is insignificant and would not require the installation of a dedicated feeder.



Figure 3. Existing Electrical Distribution System

3.2 MEDIUM VOLTAGE POWER DISTRIBUTION

Power and communications would be required at the proposed facilities, surface radars, and communications towers. Power would originate from the existing Commonwealth Utilities Corporation powerplant. Feeder taps on the existing 13.8-kilovolt USAGM overhead Feeder 4 would be required to support the facilities, surface radars, and communications towers.

Communications would originate from the Tinian commercial internet service provider hub, east of the Commonwealth Utilities Corporation power plant.

The electrical feeder and communications lines would be routed to the proposed facilities and surface radar towers via underground distribution. Surface radar towers supported via underground feeders would provide less maintenance, increased reliability and less cost in operating than if were supported by generators. However, initial cost of using generators would be substantially less. The underground distribution would include concrete-encased duct banks and medium-voltage utility holes. Utility holes would be installed at each change in direction and spaced not greater than 400 feet on straight runs as indicated per Unified Facilities Criteria 3-550-01 (DoD 2019). Where tapped from the existing overhead line, additional overhead power equipment and a riser would be required for the proposed distribution. Additional coordination with Commonwealth Utilities Corporation would be required for any outages during cutover of the 13.8-kilovolt feeder to the proposed operations.

Figure 4 reflects the proposed routing of the underground distribution for both power and communications. Further site investigation is required to verify the exact routing of the underground duct bank and utility hole locations to support the proposed operations. Duct bank configurations, utility hole sizes, and exact cable termination points would be deferred and determined during the detailed design effort.

3.2.1 Electrical Distribution System

The existing 13.8-kilovolt Commonwealth Utilities Corporation overhead line running north along 8th Street would be tapped at the power poles to provide underground lateral feeds to the proposed operations, except for the Base Camp and the communications towers.

The demobilization of the former USAGM facilities would allow reuse of the existing medium voltage distribution to support the Base Camp. An existing medium voltage switchgear would remain in place to be used from site electrical distribution. It was noted that the existing switchgear requires repair to the existing bus. The extent of the repair to the switchgear is currently unknown.

The feeder and communications lines would continue underground to the north approximately 2,000 feet east of Runway Baker to feed the two surface radar locations, the Multi-Purpose Maneuver Range, AHA1, and wells.

The feeder would also branch at 86th Street due west to support Base Camp Well Field – Option A or due east towards Base Camp Well Field – Option B, the preferred option.

A recently installed extension of Feeder 4 located north of the Francisco Manglona Borja/Tinian International Airport as part of the Tinian Divert Infrastructure Improvements would be tapped and routed underground to feed the proposed aircraft shelter.

Impacts to the existing electrical and communication systems on the neighboring Island of Saipan have been explored for training activities. No training activities would be conducted at the USAGM site on Saipan. Military traffic would be limited to occasional inspection and maintenance of the communication antenna. Replacement of the existing high-powered shortwave transmission station tower with lower-powered Radio Frequency antennas would either offset or result in a net increase of the existing electrical distribution capacity. Consequently, there would be no impact to the electrical distribution at this site on Saipan.



Figure 4. Proposed Electrical Distribution System

3.3 QUANTITIES – UNDERGROUND DISTRIBUTION

Below is a summary of the anticipated quantities of utility holes, trenching, and backfill for both the electrical and communications underground distribution systems.

This underground distribution includes approximately 85,665 linear feet of underground duct bank with 121 electrical utility holes and 221 communication utility holes. Table 2 provides the estimated quantity of duct bank (excavation, backfill, and concrete).

Table 2. Duct Bank Quantities

| <i>Type</i> | <i>Total + 15% Contingency (Cubic Yards)</i> |
|-------------|--|
| Excavation | 36,037 |
| Concrete | 14,299 |
| Backfill | 18,818 |

Legend: % = percent.

4 REFERENCES

- DON. 2018. *Electrical Study Update V2a1 Final in Support of the Commonwealth of the Northern Mariana Islands Joint Military Training Environmental Impact Statement/Overseas Environmental Impact Statement*. JBPHH, HI. Prepared for NAVFAC Pacific.
- DoD. 2019. *Unified Facilities Criteria (UFC), Exterior Electrical Power Distribution*. UFC 3-550-01. Including Change 3. November 1.

ATTACHMENT A CALCULATIONS

This page is intentionally left blank.

Base Camp Load Schedule

Tinian Base Camp Structures

| Facility Name | Unit of Measure | Quantity/Size | Watt/SF | Watt/EA | Calculated (kW) | Calculated (kVA) | Total kVA inc. 25% spare | Xfmr size (kVA) | Total Demand (kVA) | Assumption & Notes |
|---|-----------------|---------------|---------|----------|-----------------|------------------|--------------------------|-----------------|--------------------|---|
| Outdoor Services | | | | | | | | | | |
| Ammunition Holding Area (AHA-1) | SF | 100 | 2.19 | | 0.22 | 0.27 | 0.34 | 7.5 | | |
| Bivouac Concrete Pad | SF | 1 | 0 | | 0.00 | 0.00 | 0.00 | 0 | | Electrical needs provided by generators |
| Biosecurity/Washrack | SF | 5,400 | 0.15 | | 0.81 | 1.01 | 1.27 | 7.5 | | |
| Facilities | | | | | | | | | | |
| Administration/HQ Building | SF | 2,115 | 24 | | 50.76 | 63.45 | 79.31 | 112.5 | | |
| Range Control Building (Admin) | SF | 4,155 | 7.5 | | 31.16 | 38.95 | 48.69 | 75 | | |
| Base Camp | SF | 1 | 0 | | 0.00 | 0.00 | 0.00 | 0 | | Electrical needs provided by existing USAGM service |
| Warehouse | SF | 18,000 | 2 | | 36.00 | 45.00 | 56.25 | 75 | | |
| Exercise Control (Training Unit Operational Facility) | SF | 1,000 | 6 | | 6.00 | 7.50 | 9.38 | 15 | | |
| Restroom/Shower | SF | 5,700 | 2 | | 11.40 | 14.25 | 17.81 | 25 | | |
| Miscellaneous Facilities | | | | | | | | | | |
| Surface Radar 1 | EA | 1 | | 12500.00 | 12.50 | 15.63 | 19.53 | 25 | | |
| Surface Radar 2 | EA | 1 | | 12500.00 | 12.50 | 15.63 | 19.53 | 25 | | |
| Communications Towers | EA | 3 | 0 | | 0.00 | 0.00 | 0.00 | 0 | | Electrical needs provided by existing USAGM service |
| Hardened Aircraft Shelter | SF | 20,020 | 6 | | 120.12 | 150.15 | 187.69 | 225 | | |
| Well Field Monitor | EA | 2 | | 750.00 | 1.50 | 1.88 | 2.34 | 7.5 | | (2) Sensor, (1) Data Logger, Aux. Equip., Lighting |
| Fueling/Fuel Tanks | SF | 1,500 | 0.5 | | 0.75 | 0.94 | 1.17 | 7.5 | | |
| | | | | | | | | 607.5 | 182.25 | Demand kVA based on 30% of the sum of all transformer ratings |
| | | | | | | | | | 145.8 | Demand kW with 0.8 PF |

Legend: % = percent; Admin = administration; USAGM = United States Agency for Global Media; Aux. = auxiliary; EA = each; HQ = headquarters; kVA = kilovolt ampere; kW = kilowatt; PF = power factor; SF = square foot; Xfmr = transformer.

Duct Bank - Quantities

| | | <i>L (FT.)</i> | <i>W (FT.)</i> | <i>D (FT.)</i> | <i>Cross Section Area (FT.)</i> | <i>CU. FT.</i> | <i>CU. YD</i> | <i>All Conduit Areas</i> | |
|-------------------------|------------|----------------|----------------|----------------|---------------------------------|----------------|---------------|---------------------------|----------|
| Power/Comm | Excavation | 53138.56 | 3.50 | 3.83 | 13.41 | 712322.34 | 26382.31 | sqin. | Sqft. |
| | Concrete | 53138.56 | 3.50 | 1.83 | 5.30 | 281678.63 | 10432.54 | 95.00 | 0.66 |
| | Backfill | 53138.56 | 3.50 | 2.00 | 7.00 | 371969.89 | 13776.66 | 64.00 | 0.44 |
| | | | | | | | | 159.00 | 1.10 |
| Comm | Excavation | 45376.48 | 1.50 | 3.83 | 5.75 | 260687.89 | 9655.11 | <i>Comm Conduit Areas</i> | |
| | Concrete | 45376.48 | 1.50 | 1.83 | 2.30 | 104391.12 | 3866.34 | sqin. | Sqft. |
| | Backfill | 45376.48 | 1.50 | 2.00 | 3.00 | 136129.44 | 5041.83 | 64.00 | 0.44 |
| | | | | | | | | 64.00 | 0.44 |
| <i>TOTALS</i> | | | | | | | | | |
| | | | | | | | | <i>CUBIC YARDS</i> | |
| Total + 15% Contingency | | | | | | | | Excavation | 36037.42 |
| | | | | | | | | Concrete | 14298.88 |
| | | | | | | | | Backfill | 18818.49 |

Legend: % = percent; Comm = communications; CU. FT. = cubic foot; CU. YD = cubic yard; D = depth; FT. = foot or feet; L = length; squin. = square inch; Sqft. = square foot; W = width.

Electrical Distribution System – Quantities

| <i>Route Segments</i> | <i>Connecting Segment Numbers</i> | <i>Route Description</i> | <i>Routing Type</i> | <i>Length (Feet)</i> | <i>Number of Poles @135' Spacing</i> | <i>Number of Manholes @400' Spacing</i> | <i>Length (Meters)</i> | <i>Notes</i> |
|-----------------------|-----------------------------------|---|--|----------------------|--------------------------------------|---|------------------------|---|
| Segment 1 | A to B | Existing OH electrical to Tinian Powerplant | Existing Electrical (OH) | 9,823 | | | 2,994 | Tinian Powerplant to Airport, existing poles. |
| Segment 2 | B to C | Existing UG electrical to Tinian Powerplant | Existing Electrical (UG) | 2,810 | | 8 | 856 | West of Tinian International Airport clearance zone (west), required to be underground. |
| Segment 3 | C to D | Existing OH electrical to USAGM | Existing Electrical (OH), Proposed Comm (OH) | 17,392 | | | 5,301 | Existing USAGM Feeder from Airport to Base Camp would connect wells in Well Option A Site. Comm installed on existing OH poles. |
| Segment 4 | E to F | Proposed UG electrical and comm lines | Proposed Elec/Comm (UG) | 11,205 | | 29 | 3,415 | Base Camp to Surface Radar Site 1. |
| Segment 5 | G to H | Proposed UG electrical and comm lines | Proposed Elec/Comm (UG) | 13,381 | | 34 | 4,079 | Unai Chulu Road to Ushi Point Road. |
| Segment 6 | H to J | Proposed UG electrical and comm lines | Proposed Elec/Comm (UG) | 5,260 | | 14 | 1,603 | Proposed UG from 8th Avenue To North Comm Tower. |
| Segment 7 | H to K | Proposed UG electrical and comm lines | Proposed Elec/Comm (UG) | 4,763 | | 13 | 1,452 | Ushi Point Road to AHA 1 (lighting, comms), also connects MPMR water tanks/wells. |
| Segment 8 | L to M | Proposed UG electrical and comm lines | Proposed Elec/Comm (UG) | 11,599 | | 30 | 3,535 | Proposed UG elec/comm from 8th Avenue to Well Field Option B (connects wells). |
| Segment 9 | L to O | Proposed UG comm lines | Proposed Comm (UG) | 26,236 | | 67 | 7,997 | Base Camp to Broadway (inside MLA Boundary). |
| Segment 10 | N to P | Proposed UG comm lines | Proposed Comm (UG) | 13,222 | | 34 | 4,030 | Broadway MLA to Commercial Internet Service Provider (San Jose). |
| | | | | | Total Comm OH Poles | 0 | | |
| | | | | | Total Elec OH Poles | 0 | | |
| | | | | | Total # Poles | 0 | | |
| | | | | | Total Comm Manholes | 221 | | |
| | | | | | Total Elec Manholes | 121 | | |
| | | | | | Total # of Manholes | 342 | | |
| | | | | | MH Spacing | 400 | | |
| | | | | | Pole Spacing | 135 | | |

Legend: ADN = area distribution node; AHA = Ammunition Holding Area; Comm = communications; Elec = electrical; MLA = Military Lease Area; MPMR = Multi-Purpose Maneuver Range; OH = overhead; UG = underground; USAGM = United States Agency for Global Media.

This page is intentionally left blank.